

ES100 UPS Monitoring

Choosing a compatible UPS

The ES100 requires that the UPS have the following:

- 1/ A network card for local monitoring
- 2/ That the network card/UPS support SNMP standard RFC1628

Tested Fully Compatible UPS Manufacturers:

- ♦ Eaton "P" Series with Network Card-MS
- ♦ Tripp Lite SmartPro with WebcardLX

Tested Partially Compatible UPS Manufacturers:

- ♦ APC Smart UPS with AP9630 network management card

Install the UPS

- 1/ Install the UPS according to the manufacturer instructions
- 2/ Assign the UPS an IP address in the range of your monitored network
- 3/ Connect the UPS to the Network

Configure the ES100

- 1/ Launch the ES100 Configuration Tool client software.



- 2/ Click on the Devices Tab  and locate the UPS in the list. Authorize and name the device

- 3/ Click on the UPS Watch Icon: 






- 4/ Locate the UPS in the Device List and click on it to select it:

- 5/ Press the "Add to List" button:

Add to List->

- 6/ In the UPS List, Enable the UPS by clicking the Enabled check box:

UPS List:

Name/Location	Ip Address	Enabled	Manufacturer	Community	Test	Delete
Production Area UPS	192.168.0.109	<input checked="" type="checkbox"/>	American Power Conve	public		
Main IT UPS	192.168.0.81	<input checked="" type="checkbox"/>	Eaton Corporation	public		
Accounting Closet UPS	192.168.0.113	<input checked="" type="checkbox"/>	Tripp Lite	public		

Device List - Click to Select a UPS

-	0.0.0.0	D-Link International
Main IT UPS	192.168.0.81	Eaton Corporation
-	0.0.0.0	Intel Corporate
-	192.168.0.102	Intel Corporate

- 7/ Click the Test Icon:



- 8/ One of these messages will confirm the compatibility of your UPS:

UPS uses SNMP Standard RFC1628 and can be monitored with the EdgeSentry.

Close

UPS uses parts of the SNMP Standard RFC1628 and the EdgeSentry will only provide alerts based on UPS Battery Power remaining

Close